

# UL 1995 4th Edition

## Top 5 Key Changes

Intertek

Valued Quality. Delivered.



While there are many changes associated with UL 1995 4th Edition, this quick guide highlights the top 5 that you need to be aware of to ensure your product is compliant by Intertek's deadline of February 27, 2015. For a full list of the changes and additional resources, please visit [intertek.com/ul-1995](http://intertek.com/ul-1995).

- 1 Electric Heat Controllers:** Electric heat controllers shall break all ungrounded conductors. Phase breaking is not permitted.
- 2 Contactors used in Pressure-limiting Circuits:** Contactors used in pressure-limiting circuits shall have an endurance rating of 100,000 cycles or more.
- 3 Requirements for Certification on Electronically Protected Motor Circuits:** The protective circuits shall meet specific requirements of the applicable UL/CSA standards based on the application and degree of protection.
- 4 Loading Test on Ceiling and Wall Suspended Equipment:** The equipment must withstand up to three times its weight (no more than 400 lbs) for one minute.
- 5 Requirements for Units Utilizing Motors with Wave Chopping Solid State Speed Devices:** Half wave test on motors required.

### Your Single Source Solution for UL 1995 4th Edition

- Contact Intertek to help you develop a strategy to get your files updated by the deadline.
- We provide easy and cost effective solutions for converting your safety certifications to Intertek and updating to the 4th Edition simultaneously.
- For more information contact [icenter@intertek.com](mailto:icenter@intertek.com) or 1-800-WORLDFAB, or visit [www.intertek.com/ul-1995](http://www.intertek.com/ul-1995)